

Date: July 20, 2016

Project: Kake Bulk Fuel and Rural Power
System Upgrades

Solicitation No.: 16155

Addendum No. Four

TO ALL PLANHOLDERS:

The enclosed addendum amends the proposal documents for the above referenced Project.

Acknowledgment of this addendum is required on the Proposal Submittal. Failure to do so may subject the proposer to disqualification.

Sincerely,

Rich Wooten, CDT, CPSM
Contracting Officer

ADDENDUM TO CONTRACT DOCUMENTS	Page Number 1	No. of Pages One
Addendum No. FOUR	Date Addendum Issued: July 20, 2016	
Issuing Office Rich Wooten, CDT, CPSM Alaska Industrial Development Export Authority 813 W Northern Lights Blvd Anchorage, AK 99503 Phone: (907) 771-3019 Fax: (907) 771-3044	Previous Addenda Issued Addendum One, July 5, 2016 Addendum Two, July 11, 2016 Addendum Three, July 15, 2016	
Project: Kake Bulk Fuel and Rural Power System Upgrades Solicitation No.: 16155	Date and Hour Quotes Due: July 28, 2016 at 3:00 p.m., prevailing Anchorage time.	

NOTICE TO PROPOSERS:

Proposers must acknowledge receipt of this addendum prior to the hour and date set for proposal due date by one of the following methods:

- (a) By acknowledging receipt of this addendum on the proposal form submitted.
- (b) By email or telefacsimile which includes a reference to the project and addendum number.

The proposal documents require acknowledgment individually of all addenda to the drawings and/or specifications. This is a mandatory requirement and any proposal received without acknowledgment of receipt of addenda may be classified as not being a responsive proposal. If, by virtue of this addendum it is desired to modify a proposal already submitted, such modification may be made by email or telefacsimile provided such an email or telefacsimile makes reference to this addendum and is received prior to the opening hour and date specified above.

The Proposal documents for the above project are amended as follows (All other terms and conditions remain unchanged):

PROPOSAL AND CONTRACT REQUIREMENTS

BIDDING AND CONTRACT DOCUMENTS

A. Modifications to Bidding and Contract Documents

1. Section 15191 Fuel Piping System, Article 1.03 Performance Requirements, Paragraph B, Item 2 (Page 15191-1):

Delete Item 2 in its entirety and replace with the following:

- A. Operating temperature range: -20°F to 120°F

2. Section 15191 Fuel Piping System, Article 2.02 Pipe, Paragraphs A and B, (Page 15191-3)

Delete Paragraphs A and B in their entirety and replace with the following:

- A. Steel Pipe: All steel pipe shall be Schedule 80, Seamless, ASTM A106B. 2” and 3” pipe shall be provided in double random lengths (42’ nominal).
- B. Steel Pipe Nipples: ASTM A53 steel, schedule to match adjoining.

END OF ADDENDUM